

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89285
 Permit No. 103
 Basin 103
 NOTICE OF INTENT NO. 46417

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **STEVE OBRIAN**
 MAILING ADDRESS **1619 SCOTTIE LANE GARDNERVILLE, NV 89410**
 ADDRESS AT WELL LOCATION **230 SUTRO LANE DAYTON, NV 89403**

2. LOCATION SW 1/4 SW 1/4 Sec 9 T 16 N R 22 E LYON County
 PERMIT NO. 16-352-09

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
COURSE SANDS		3	6	3
BROWN CLAY		6	31	25
COURSE DG SANDS		31	87	56
BROWN CLAY		87	146	59
FRACTURED DG SANDS	XXX	146	190	44

8. WELL CONSTRUCTION
 Depth Drilled 190 Feet Depth Cased 190 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 0 Feet 190 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>190</u>

Perforations:
 Type perforation **FACTORY MILL SLOT**
 Size perforation **3 X 3/32**
 From 170 feet to 190 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 190 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 6/4, 20 02
 Date completed 6/6, 20 02

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		
	<u>25</u>	<u>35</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **CAPITAL CITY WELL DRILLING**
 (CONTRACTOR)
 Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Stuck
 By driller performing actual drilling on site or contractor
 Date 6/10/02

RECEIVED
 02 JUN 19 AM 9:17
 STATE ENGINEERS OFFICE