


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89296
 Permit No. _____
 Basin 137-B



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50841

1. OWNER Round Mountain Gold Corp. DW-31 ADDRESS AT WELL LOCATION Round Mountain Gold minesite, Round Mountain, NV.
 MAILING ADDRESS P.O. Box 480 Round Mountain, NV 89045

2. LOCATION SW 1/4 SE 1/4 Sec. 24 T 10N N/S R 43E E Nye County
 PERMIT NO. 68463-T 68462-T N/A Parcel No. N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Fld Rvs

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium		0	930	930
Construction Detail:				
Cement		0	50	50
Hole plug		50	390	340
Gravel pack		390	930	540

8. WELL CONSTRUCTION
 Depth Drilled 930 Feet Depth Cased 920 Feet

HOLE DIAMETER (BIT SIZE)
 From To
26 Inches 0 Feet 20 Feet
19 Inches 20 Feet 930 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>22</u>	<u>57.405</u>	<u>.250</u>	<u>0</u>	<u>20</u>
<u>12.750</u>	<u>49.56</u>	<u>.375</u>	<u>+2</u>	<u>920</u>

Perforations:
 Type perforation Wire Wrapped
 Size perforation .080"

From <u>460</u> feet to <u>920</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 390 feet to 930 feet

Date started 5/8/2002, 19
 Date completed 5/15/2002, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>05/15/2002</u>	<u>231</u>	<u>67.8</u>	<u>1 Hour</u>

9. WATER LEVEL
 Static water level 437.9 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I.
 Water temperature 110 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2144

Signed Paul Stoddard
 By driller performing actual drilling on-site or contractor
 Date 5/22/02

Plugged by well log 123140 B.S.L.