

OFFICE USE ONLY
 Log No. 89352
 Permit No. _____
 Basin 084

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40352

1. OWNER BOEING NORTH AMERICAN, INC. ADDRESS AT WELL LOCATION Rocketdyne
 MAILING ADDRESS 6633 Canoga Avenue Former NFL-Area D
Canoga Park, California 91309 Whiskey Springs Road, Reno, NV 89510
 2. LOCATION NW 1/4 NW 1/4 Sec. 8.13 T. 22N N/S R. 21 E. Washoe County
 PERMIT NO. DEX-10, 077-110-12 Palomino Valley Dist
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light reddish brown gravel-sand-silt mix, dry, cobbles & boulders	@ surface	0	4	4
Reddish brown gravel-sand-clay mix, water added, fine coarse sands, fine-coarse gravels, subrounded-subangular, well graded, some clay		4	17	13
Reddish brown clayey-sands, water added, fine-coarse sands, subrounded, moderately graded, some fine-coarse gravels		17	24	7
Large boulders		24	27	3
Medium brown gravel-sand-clay mix, water added, med-coarse sands, fine-coarse gravels, sub-rounded-sugangular, well graded, some clay		27	38	11
Large boulder		38	41	3
Reddish brown clayey gravels		41	45	4
Medium brown gravel-sand mix, water added, fine-coarse sands, fine-coarse gravels, subrounded-subangular, well graded		45	65	20
Reddish brown clayey gravels		65	67	2
Medium brown gravel-sand mix, saturated, fine-coarse sands, fine-coarse gravels, subrounded-subangular, well graded, trace of clay		65	77	12
Grayish med. rhyolite tuff		77	80	3

8. WELL CONSTRUCTION
 Depth Drilled 80 Feet Depth Cased 79.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 80 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8 x .188	0-16 ft/6"	Stainless Steel	16-19.5	
6 5/8 x 3/8"	steel adaptor/			
	Welded stainless bottom cap		79.4	75.5

Perforations:
 Type perforation Stainless Steel/factory slot
 Size perforation .020 wire wrap
 From 19.5 feet to 79.5 feet
 From _____ feet to _____ feet
 From Surface completion 0-4ft.
 From 4x4x4 open bottom concrete vault
 From with metal lid

Surface Seal: Yes No Seal Type:
 Depth of Seal 4 ft to 13 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite seal: 13 ft to 16 ft.
 Gravel Packed: Yes No #30 sand 16 ft.-17 ft.
 From 17'-80' #8 Lonestar Sand _____ feet

9. WATER LEVEL
 Static water level 62.20 feet below land surface
 Artesian flow not known G.P.M. _____ P.S.I. _____
 Water temperature cold °F Quality clear

Date started October 8, 1999, 19_____
 Date completed October 12, 1999, 19_____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date June 24, 2002

RECEIVED
 JUL 15 2002
 STATE ENGINEERS OFFICE