

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48342

1. OWNER DAVE MAUK ADDRESS AT WELL LOCATION 1968 Arabian Wy Gardnerville, Nev 89410
 MAILING ADDRESS P.O. Box 986 Gardnerville, NV 89410
 2. LOCATION SE 1/4 NE 1/4 Sec 24 T 12 N R 20 E Douglas County
 PERMIT NO. 1220-24-601-052 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE: Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE: Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------------|--------------|------------|------------|------------|
| <u>NATIVE BROWN SAND</u> | | <u>0</u> | <u>15</u> | <u>15</u> |
| <u>BROWN BLACK ROCK SAND</u> | | <u>15</u> | <u>100</u> | <u>85</u> |
| <u>BROWN CLAY</u> | | <u>100</u> | <u>107</u> | <u>7</u> |
| <u>GREEN + GREY ROCK</u> | | <u>107</u> | <u>130</u> | <u>23</u> |
| <u>BROWN CLAY</u> | | <u>130</u> | <u>141</u> | <u>11</u> |
| <u>BROWN GREY BLACK ROCK</u> | | <u>141</u> | <u>200</u> | <u>59</u> |
| <u>BROWN GREEN CLAY</u> | | <u>200</u> | <u>210</u> | <u>10</u> |
| <u>BROWN BLACK GREEN X</u> | | <u>210</u> | <u>280</u> | <u>70</u> |
| <u>Red, white rock</u> | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 280 Feet
 HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 To 280 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 1/2</u> | | <u>.188</u> | <u>0</u> | <u>280</u> |

Perforations:
 Type perforation FACTORY
 Size perforation _____
 From 240 feet to 280 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 5'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 280 feet to 50 feet

9. WATER LEVEL
 Static water level 82 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA PUMP & DRILLING
 Address P.O. BOX 2227 DAYTON, NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 0046357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
 Signed Thomas Evans
 By driller performing actual drilling on site or contractor
 Date 5-7-02

Date started 4-24-02, 20____
 Date completed 4-27-02, 20____

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>30</u> | | <u>2</u> |

RECEIVED
 APR 16 AM 5:11
 STATE ENGINEER'S OFFICE