

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 89355
Permit No.
Basin. 284

NOTICE OF INTENT NO 45826

1. OWNER PHIL HULSEY ADDRESS AT WELL LOCATION PRAIRIE AND JACKRABBIT
MAILING ADDRESS PO BOX 2901 Sparks NV 4905 JACKRABBIT ROAD
2. Location SE 1/4 SE 1/4 Sec 10 T 22N R 2E Washoe County
PERMIT NO. PARCEL NO. 76-130-16 SUBDIVISION NAME 20

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	<input checked="" type="checkbox"/> Air	Other	Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
Top soil natural fill		0	50	50
Brown Decomposed granite.		50	70	20
Cement colored rock medium hard.		70	295	225
Fractured rock		295	394	99

8. WELL CONSTRUCTION					
Depth Drilled	394 feet	Depth Cased	394 feet	HOLE DIAMETER (BIT SIZE)	
				From	To
	11 inches		0 feet	55 feet	55 feet
	8 3/4 inches		55 feet	394 feet	394 feet
CASING SCHEDULE					
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
6 5/8	12.94	188	+1 1/2	394	
Perforations::					
Type Perforation	Factory				
Size perforation	3/32 x 3"				
From	294 feet	to	334 feet		
From	354 feet	to	394 feet		
From		to			
From		to			
From		to			
From		to			
Surface Seal <input checked="" type="checkbox"/> YES No Seal Type: Neat Cement					
Depth of Seal 52 feet <input checked="" type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured <input checked="" type="checkbox"/> Cement Grout <input checked="" type="checkbox"/> Concrete Grout					
Gravel Packed: <input checked="" type="checkbox"/> Yes No					
From 52 feet to 394 feet					
9. WATER LEVEL					
Static water level	224 feet	below land surface			
Artesian flow	0 GPM	0 P.S.I.			
Water Temperature	cold	Degrees F	Quality		

Date started 10-23 -01
Date completed 10-26 -01

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	x Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)	
12	70		
25	125		
42	170		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc.
2290 Pioneer Drive
Reno, NV 89509
NV Contractors No. 14170
NV Driller's Lic (on site) 2010
Signed *Steve McKay*
By driller performing actual drilling on site or contractor
Date 11-22 -01