

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 89382  
 Permit No. 099  
 Basin 099  
 NOTICE OF INTENT NO. 47932

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER Chris Hall ADDRESS AT WELL LOCATION 555 Clysedale Dr  
 MAILING ADDRESS 555 Clysedale Dr Reno NV 89506  
 2. LOCATION NE 1/4 SE 1/4 Sec. 33 T 24 S R 18 E Washoe County Reno  
 PERMIT NO. 079-311-05 Subdivision Name Rancho Haven

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	15	15
Clay & Rock		15	75	60
Clay & Red Rocks		75	345	270
Clay Gray		345	355	10
Rock (Fract)	✓	355	415	60
Sticky Gray Clay		415	535	120
Rock Fract	VV	535	575	40

8. WELL CONSTRUCTION  
 Depth Drilled 575 Feet Depth Cased 375 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 300 Feet  
8 3/4 Inches 300 Feet 575 Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>3/16</u>	<u>2+</u>	<u>575</u>

Perforations:  
 Type perforation Saw Slot  
 Size perforation 3/16  
 From 355 feet to 415 feet  
 From 535 feet to 575 feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 575 feet

RECEIVED  
 02 DEC -2 PM 12:33  
 STATE ENGINEERS OFFICE

Date started 10/19/02  
 Date completed 10/28/02

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>200'</u>	<u>6.5</u>

9. WATER LEVEL  
 Static water level 28' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge,  
 Name Olencki Drilling & Pump Co  
 Address 15045 Red Rock Rd  
Reno NV 89506  
 Nevada contractor's license number 50343  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656  
 Signed John F. Olencki  
 By driller performing actual drilling on site or contractor  
 Date 11/17/02