

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89406
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 584.340

NOTICE OF INTENT NO. **48754**

1. OWNER Wes Tews ADDRESS AT WELL LOCATION 1758 Bafford lane,
 MAILING ADDRESS 3480 Schurz Hwy Fallon, NV 89406

2. LOCATION NE 1/4 SE 1/4 Sec. 17 T 19N N/S R 29E E Churchill County
 PERMIT NO. 007-391-22 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Brown Clay		3	17	14
Brown Sand		17	32	15
Black Clay		32	35	3
Black Sand		35	39	4
Gray sand		39	65	26
Gray Clay		65	70	5
Brown sand		70	97	27
Brown Silt		97	120	23
Gray Clay		120	135	15
Gray Sand		135	172	37
Gray Silt		172	189	17
Black Clay		189	210	21
Gray Sand		210	230	20
Gray Clay		230	233	3
Gray Sand		233	250	17
Brown Clay		250	260	10
Grayish Sand		260	270	10
Brown Sand	XX	270	290	20

8. WELL CONSTRUCTION
 Depth Drilled 290 Feet Depth Cased 290 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 290 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.92	.258	20	290

Perforations:
 Type perforation saw cut
 Size perforation 1/8
 From 285 feet to 290 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 290 feet

9. WATER LEVEL
 Static water level 36 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon Nv. 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed William Parsons
 By driller performing actual drilling on-site or contractor
 Date 04/17/2003

Date started 03/14/2003 , 19
 Date completed 03/21/2003 , 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>1hr</u>