REPORT NO. A03.019

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 89408
PERMIT NO.
BASIN 083

NOTICE OF INTENT NO. 49979

OWNER Harry Varnum
MAILING ADDRESS

ADDRESS OF WELL 2418 Cartwright Rd.
VC Highlands, NV 89521

2. WELL LOCATION NE 1/4 NW 1/4 SEC. 32 T 18 R 21 E Storey COUNTY

PERMIT NO PARCEL NO 03-021-09 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Dark Purple White Specks		298	330	32
Red Volcanic Dark Purple		330	530	200
Dark Purple White Specks		530	634	104

8. WELL CONSTRUCTION
Depth Drilled 634 Depth Cased 298

HOLE DIAMETER (BIT SIZE)
6 1/4 Inches 298 Feet 634 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To

PERFORATIONS:
Type Perforation Size Perforation
From Feet to Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From Feet to Feet

Notes: INSUFFICIENT WATER
NEW WELL BEING DRILLED
WILL PLUG THIS WELL WHEN COMPLETE

9. WATER LEVEL
Static Water Level 340 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

Date Started Feb 11, 2003 Date Completed Feb 14, 2003

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	1 1/2	Blow hole to	check GPM

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed
By driller performing actual drilling on site or contractor

Dated March 25, 2003