

Log No. 89420
 Permit No. _____
 Basin. 9D

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NRS 534.340

NOTICE OF INTENT NO. _____

1. OWNER GLENBROOK HOMEOWNERS ASSN. ADDRESS AT WELL LOCATION GLENBROOK GOLF COURSE
 MAILING ADDRESS GLENBROOK, NV GLENBROOK, NV
MW-3

2. LOCATION SW 1/4 SE 1/4 Sec 3 T. 14N N/S R. 18 E DOUGLAS County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Medium Brown Silty Sand (SM/SC) Fine Grained		0	5	5
Ground Water (Unstabilized)		4'		
Medium Brown Sandy Clay (SC)		5	9	4
Medium Brown Silty Clay (CL) Stiff, Wet		9	TD	3+

8. WELL CONSTRUCTION
 Depth Drilled 12 Feet Depth Cased 12 Feet

HOLE DIAMETER (BIT SIZE)
 From 3 Inches To 12 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1.5"	Sch 40	PVC	0	12

Perforations:
 Type perforation Saw Cut
 Size perforation 0.03"
 From 3 feet to 12 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 3 feet to 12 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started December 23, 1999, 19____
 Date completed December 28, 1999, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Soils Engineering of Nevada Contractor
 Address 820 Kuenzli St Reno, NV 89502 Contractor

Nevada contractor's license number issued by the State Contractor's Board N/A (P.E.)
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2045

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date April 23, 2001