

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51313

1. OWNER Rudolph Rokitta ADDRESS AT WELL LOCATION 9730 Loring Ave
 MAILING ADDRESS PO Box 1722
Winnemucca, NV
 2. LOCATION SE 1/4 NE 1/4 Sec. 30 T. 35 N/S R. 38 E Humboldt County
 PERMIT NO. Domestic 010-644-07 Parcel No. 1ycana Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Topsoil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Builders + Gravel</u>		<u>3</u>	<u>100</u>	<u>97</u>
<u>Clay</u>		<u>100</u>	<u>140</u>	<u>40</u>
<u>Sandish Gravel</u>		<u>140</u>	<u>150</u>	<u>10</u>
<u>Clay</u>		<u>150</u>	<u>270</u>	<u>120</u>
<u>Sand + Fine Gravel</u>	<u>Yes</u>	<u>270</u>	<u>300</u>	<u>30</u>
<u>Clay + Fine Gravel</u>		<u>300</u>	<u>360</u>	<u>60</u>

8. WELL CONSTRUCTION
 Depth Drilled 360' Feet Depth Cased 360' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 4 1/2 Feet 360 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1.88</u>	<u>+1</u>	<u>360</u>

Perforations:
 Type perforation Factory cut
 Size perforation 3/32 x 4
 From 310 feet to 360 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 48' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 48' feet to 360 feet

9. WATER LEVEL
 Static water level 222 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 60.1 °F Quality Good

Date started July 24th 2002
 Date completed July 28th 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>34.2</u>		<u>5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson + Sons Drilling Contractor
 Address 10760 Grass Valley Rd Contractor
Winn NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date Aug 1st 2002