



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51050

1. OWNER Hawthorne Army Depot ADDRESS AT WELL LOCATION Hawthorne Army Depot
 MAILING ADDRESS 1 South rdine AVE Highway 95 Hawthorne, NV
Hawthorne, NV 89415 - 9404 89415
 2. LOCATION E 1/2 x NW 1/4 Sec. 11 T. 8 S. R. 30 E. Mineral County
 PERMIT NO. W/P 1252 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Road grade material | | 0 | 3 | 3 |
| well graded BRN clayey - sand, and some gravel | | 3 | 11 | 8 |
| well graded BRN clayey - sand @ coarse gravel | | 11 | 21 | 10 |
| poorly graded fine sand olive-tan uoc odor | | 21 | 30 | 9 |
| sandy-gravels tan to BRN some uoc odor | | 30 | 42 | 12 |
| well graded BRN to rounded sandy gravel | | 42 | 57 | 15 |
| silty - coarse sand | | 57 | 68 | 11 |
| silty sand @ BRN clay moist | | 68 | 85 | 17 |
| silty - fine sand wet BRN | | 85 | 101 | 16 |
| water zone | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 101 Feet Depth Cased 100.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 101 Feet
 Inches.....Feet.....Feet
 Inches.....Feet.....Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>3/4"</u> | <u>PVC</u> | <u>sch. 80</u> | <u>0</u> | <u>98</u> |

Perforations:
 Type perforation 0 zone mixed screen
 Size perforation 5/16"
 From 98 feet to 100.5 feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 91 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 96.5 feet to 101 feet

9. WATER LEVEL
 Static water level NA feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Layne Christensen Contractor
 Address 11001 E Hiwanda Ave Contractor
Fontana - CA 92337
 Nevada contractor's license number issued by the State Contractor's Board 0819101
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1468
 Signed Stephan Johnson driller performing actual drilling on site or contractor
 Date 10-14-02

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 Draw Down (Feet Below Static) Time (Hours)
 Date started 10-10-02
 Date completed 10-10-02
 RECEIVED 10/10/02 OFFICE
 STATE ENGINEER
 1101072