WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89455
Permit No.
Basin 083

NOTICE OF INTENT NO. 485[illegible]

1. OWNER Canyon G.I.D. MW-5
MAILING ADDRESS 400 Canyon Way
Sparks, NV 89435

ADDRESS AT WELL LOCATION 400 Avenue de Coleurs,
Lockwood, NV

2. LOCATION NW 1/4 SE 1/4 Sec. 16 T 19N N/S R 21E E Storey County
PERMIT NO. NEV-50028 Issued by Water Resources
003-558-001 Parcel No.
Rainbow Bend Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Fill		0	3	3
Clay and gravel		3	8	5
Black basalt		8	16	8
Dark green and tan		16		
fractured basalt			28	12
Dark green and black		28		
basalt			40	12
Construction Detail:				
Cement		0	12	12
Gravel pack		12	33	21
H[illegible]plug		33	40	7

Date started 4/17/2003 , 19__
Date completed 4/17/2003 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3	Not Meas.	

8. **WELL CONSTRUCTION**
Depth Drilled 40 Feet Depth Cased 32 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17.5	Inches	0	Feet	5	Feet
7.875	Inches	5	Feet	40	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	28.04	0.250	+2	5
4.5	0.21	Sch. 40	+2	32

Perforations:
Type perforation Slotted
Size perforation 0.020"
From 12 feet to 32 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 10'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 12 feet to 33 feet

9. **WATER LEVEL**
Static water level 22.7 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cool °F Quality Fair

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling
Contractor
Address P.O. Box 5279
Contractor
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2143
Signed Brant Bowen
By driller performing actual drilling on-site or contractor
Date 4/23/03

USE ADDITIONAL SHEETS IF NECESSARY

3 ST. L