WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89477
Permit No.
Basin 083

NOTICE OF INTENT NO. 50438

1. OWNER ROBERT & MELANIE MEYER
MAILING ADDRESS 3270 Epic Avenue
Reno, Nevada 89512

ADDRESS AT WELL LOCATION 455 Klofta Ct.
Sparks, Nevada 89436

2. LOCATION SW ¼ NE ¼ Sec. 2 T. 21N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-282-08 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay mixed with gravels & boulders		1	4	3
Multi-color sandy clays		4	22	18
Multi-color volcanic rock with streaks of clay		22	51	29
Light brown volcanic rock		51	142	91
Soft zone		142	144	2
Light brown volcanic rock		144	205	61
Dark brown volcanic rock		205	316	111
Brown clay		316	318	2
Gray sandy clay		318	338	20
Weathered granite		338	379	41
Fractured granite(NO H20)		379	391	12
Weathered granite, gray		391	412	21
Fracture (approx 5 GPM)	X	412	413	1
Gray granite		413	465	52
Fracture granite	X	465	490	35
Weathered granite		490	498	8

Date started 3-24-03, 20
Date completed 3-27-03, 20

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+			

8. WELL CONSTRUCTION
Depth Drilled 498 Feet Depth Cased 498 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	498 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	498

Perforations:
Type perforation Factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 401 feet to 411 feet
From 451 feet to 491 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 feet
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 498 feet

9. WATER LEVEL
Static water level 380 feet below land surface
Artesian flow 25+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 28, 2003

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627