89482

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89482
Permit No.
Basin 212

NOTICE OF INTENT NO. 24722

1. OWNER Glen Kurt Meisel
MAILING ADDRESS 9345 W. Flamingo
Las Vegas NV. 89147

ADDRESS AT WELL LOCATION 4200 W Pyle
Arville & Pyle

2. LOCATION SW ¼ NE ¼ Sec. 30 T. 22 N/S R. 61 E. Clark County

PERMIT NO. (Issued by Water Resources) 177306040 20 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders-Sand Gravel		0	110	110
Cemented Gravels		110	200	90
Brown Clay Sand Gravel		200	280	80
Boulders Gravel Sand	✓	280	410	130
Cemented Gravel	✓	410	500	90

DCNR DWR RECEIVED MAY 2 2003 LAS VEGAS OFFICE

Date started 4-28-03, 20
Date completed 5-1-03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		24 HRS

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 490 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	500 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 IN	F480	P.V.C	+1	490
5 Ft	85/8	188		

Perforations:
Type perforation Saw
Size perforation 1/8 X 12
From 490 feet to 410 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 +
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 490 feet

9. WATER LEVEL
Static water level 230 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling (Contractor)
Address 3955 Blue Diamond Rd #4 (Contractor)
Las Vegas NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
Signed Floyd Mitchell (By driller performing actual drilling on site or contractor)
Date 5-1-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627