

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89488
 Permit No. _____
 Basin 089

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **46639**

1. OWNER Lori Yazzie ADDRESS AT WELL LOCATION 3295 Churchill Drive
 MAILING ADDRESS 3295 Churchill Drive Carson City, Nevada 89704
Carson City, NV 89704

2. LOCATION SW 1/4 NE 1/4 Sec. 6 T 16N N/S R 20E E Washoe County
 PERMIT NO. _____ Parcel No. 050-444-08 Subdivision Name New Washoe City
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand and Clay		0	7	7
Fine Sand		7	118	111
Course Sand and Gravel	x	118	150	32
Total Depth 150		150	150	0

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10-5/8</u> Inches	0	150
Inches		
Inches		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+2</u>	<u>150</u>

Perforations:
 Type perforation Factory Sawed
 Size perforation 3/32 x 3

From	To
<u>120</u> feet to	<u>140</u> feet
From _____ feet to	_____ feet
From _____ feet to	_____ feet
From _____ feet to	_____ feet
From _____ feet to	_____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 150 feet

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Contractor
 Address P.O. Box 60130 Contractor
Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 35387-B
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
 Signed Tony Welch
 By driller performing actual drilling on-site or contractor
 Date 04/06/2003

Date started 03/24/2003, 19____
 Date completed 03/26/2003, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>20</u>	<u>80</u>	<u>1 hour</u>
	<u>30</u>	<u>120</u>	<u>1 hour</u>
	<u>30</u>	<u>150</u>	<u>3 hour</u>

RECEIVED
 03 APR +9 AM 10:54
 STATE ENGINEERS OFFICE