WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89489
Permit No.
Basin Ø89

NOTICE OF INTENT NO. 46640

1. OWNER Lori Yazzie
MAILING ADDRESS 3295 Churchill Drive
Carson City, NV 89704

ADDRESS AT WELL LOCATION 3295 Churchill Drive
Carson City, Nevada 89704

2. LOCATION SW 1/4 NE 1/4 Sec. 6 T 16N N/S R 20E E Washoe County
PERMIT NO. _____ Issued by Water Resources | 050-444-08 Parcel No. | New Washoe City Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Perforate Casing with				
Mills Knife from 69				
feet up to 47 feet				
found concrete				
seal.Installed 2				
trimie pipe to 69 feet				
and pump approximate				
3,667 LBS of neat				
cement to abandon well				

RECEIVED
03 APR -9 AM 10:54
STATE ENGINEERS OFFICE

Date started 04/04/2003, 19__
Date completed 04/04/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 69 Feet Depth Cased 69 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	10.79	.156	+1	69

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal Inplace
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service
Contractor
Address P.O. Box 60130
Contractor
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Larry Welch
By driller performing actual drilling on-site or contractor
Date 04/07/2003

USE ADDITIONAL SHEETS IF NECESSARY