WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89506
Permit No.
Basin 044

NOTICE OF INTENT NO. 40225

1. OWNER Anglo Gold
MAILING ADDRESS HC-31 BOX 78 ELKO, NV. 89801
ADDRESS AT WELL LOCATION Anglo Gold Jerritt Canyon

2. LOCATION SE ¼ NW ¼ Sec. 31 T. 41 (N)S R. 54 (E) ELKO County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clays - Gravels		0'	120'	
	75'			
4½ Hrs. of cleaning water is clean.				
Flush Joint Sch. 40 PVC				

Date started 4-10 2003
Date completed 4-11 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 120' Feet Depth Cased 100' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0' Feet	20' Feet
8 Inches	20' Feet	120' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	1.80	SCH. 40 PVC	0'	100'

Perforations:
Type perforation Horz. slot
Size perforation [redacted] .080
From 100' feet to 70' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 120' feet to 65' feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow NO G.P.M. 4 P.S.I. 100
Water temperature 52° °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ward Weaver
Address 2305 Last Chance Rd. (Contractor)
ELKO, NV. 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
Signed Ward Weaver (By driller performing actual drilling on site or contractor)
Date 4-11-03

RECEIVED APR 15 AM 11:
STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627