WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89513
Permit No.
Basin 207

NOTICE OF INTENT NO. 43193

1. OWNER Sandra Adams
MAILING ADDRESS 475-340 San Francisco St. Susan Ville CA. 96130
ADDRESS AT WELL LOCATION Parcel 4 Lot 7 Block 18

2. LOCATION NW ¼ NW ¼ Sec. 28 T. 17 N/S R. 62 E. White Pine County
PERMIT NO. N/A Issued by Water Resources
013-086-05 Parcel No.
Land ten acre plat Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	
gravel conglomerate		5	5'	
Sandy clay		5	14	
Cobbles gravel		14	18	
Sandy clay		18	24	
gravel con.		24	26	
Sandy clay		26	52	
gravel		52	53	
Clay		53	54	
gravel		54	55	
Sandy clay		55	62	
gravel	water	62	70	
Sandy clay		70	100	
gravel	water	100	103	
Clay Sand		103	109	
gravel	water	109	111	
Sandy clay		111	117	
gravel	water	117	118	
Sandy clay		118	130	

RECEIVED 03 MAR 20 AM 10:46 STATE ENGINEER'S OFFICE

Date started Jan 30, 2003
Date completed Feb 25, 2003

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	14'	1 hr

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	130 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	130

Perforations:
Type perforation Mill
Size perforation 3/32 x 2" x 6 row
From feet to feet
From 60 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Orvas Maynard Contractor
Address Po Box 64 Lund NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 47226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orvas Maynard By driller performing actual drilling on site or contractor
Date March 17-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627