

OFFICE USE ONLY
 L No. 89528
 Permit No. _____
 Bait No. 107
 NOTICE OF INTENT NO. 47908

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER WILLIAM TAYLOR ADDRESS AT WELL LOCATION 49 PINION DR. WELLINGTON NV, 89444
 MAILING ADDRESS 10127 VALLEY DR. SOUTH WILLIS TEXAS 77318
 2. LOCATION SW 1/4 NW 1/4 Sec 10 T. 11 N/S R. 23 E. LYON County
 PERMIT NO. 09-052-07 VALLEY VIEW RANCHOS Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY BWN. CLAY		0	65	65
HARD ROCK		65	70	5
SANDY BWN. CLAY		70	110	40
GRAANITE RDLK		110	112	2
SANDY BWN. CLAY		112	135	23
GRANITE RDLK		135	140	5
SANDY BWN. CLAY		140	195	55
HARD PRAL. ROCK	YES	195	210	15
COARSE SAND+GRAVEL	YES	210	260	50

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 55 Feet
 From 7 Inches To 55 Feet 260 Feet
 From _____ Inches To _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.188	1.5	260

Perforations:
 Type perforation FACTORY SAW SLOT
 Size perforation 1/8" X 4" X 16" OC 6 ROWS
 From 200 feet to 260 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 4-13-03, 19_____
 Date completed 5-1-03, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		<u>5</u>	<u>3</u>

9. WATER LEVEL
 Static water level 175 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDMUND MILLER DRILLING CO.
 Address PO BOX 92 SMITH NV, 89430
 Nevada contractor's license number 32166-A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 2232
 Division of Water Resources the on-site driller.
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date 5-6-03