COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99532
Permit No.
Basin 089

NOTICE OF INTENT NO. 49451

OWNER DREW PLIMPTON
MAILING ADDRESS P.O. BOX 4230
STATELINE, NV 89449

ADDRESS AT WELL LOCATION 18410 LAKE VISTA RD
WASHOE VALLEY, CARSON CITY, NV 89703

2. LOCATION NE ¼ NE ¼ Sec 3 T 16 N R 19 E WASHOE County

PERMIT NO. (Issued by Water Resources) 055-081-82 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
RUSTY SANDS		3	15	12
COURSE DG SANDS	X	15	87	72
SILTY GRAY SANDS	X	87	145	58
SANDY CLAY				
COURSE WHITE & BLACK DG SANDS	XXX	145	180	35

RECEIVED 03 MAR -4 AM 9:15 STATE ENGINEERS OFFICE

Date started 2/24, 20 03
Date completed 2/25, 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	35	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 180 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M ~~25+~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING INC. (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 3/03/03