



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46250

1. OWNER Stuart Mills ADDRESS AT WELL LOCATION 3244 Highland Way
 MAILING ADDRESS 3575 Sedwick Dr Gardnerville, NV 89400
Las Vegas NV 89129
 2. LOCATION SW 1/4 SW 1/4 Sec 18 T 10 S R 22 E Douglas County
 PERMIT NO. 1022-18-002-004 Parcel No. Holdbrook Highlands Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND + ROCK		0	10	10
SAND + GRAVEL		10	25	15
BROWN CLAY		25	30	5
SAND + BLACK, BROWN ROCK		30	100	70
SAND + LIGHT BROWN CLAY		100	115	15
BLACK GREY ROCK	✓	115	160	45
BLACK, GREY, GREEN, WHITE BROKEN ROCK	✓	160	200	40

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>200</u>	<u>0</u>

Perforations:
 Type perforation FACTORY
 Size perforation
 From 160 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 59 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 200 feet to 50 feet

Date started 12-10, 2002
 Date completed 12-13, 2002

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>		<u>3</u>

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow 0 G.P.M. 36 P.S.I.
 Water temperature COLD °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Pump & Drilling
P.O. Box 2227
 Address Dayton, NV 89403 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 046357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
 Signed Thomas Evans
 By driller performing actual drilling on site or contractor
 Date 1-26-03