

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 29543  
 Permit No. \_\_\_\_\_  
 Basin 103  
 NOTICE OF INTENT NO. 49413

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **SCOTT SNELLING CONSTRUCTION** ADDRESS AT WELL LOCATION **205 POTOSI DAYTON, NV 89403**  
 MAILING ADDRESS **318 SYDNEY LN DAYTON, NV 89403**

2. LOCATION **SE 1/4 SE 1/4 Sec 9 T 16 N R 22 E LYON County**

PERMIT NO. **19-441-07** Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BLOW SANDS		0	3	3
HARDPAN SANDS		3	6	3
SANDY BLOW SANDS		6	21	15
COURSE DG SANDS		21	87	66
BROWN CLAY		87	146	59
GRAY CLAY		146	167	21
FRACTURED DG SAND	XXX	167	200	33

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 3/4 Inches 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200

Perforations:  
 Type perforation **FACTORY MILL SLOT**  
 Size perforation **3 X 3/32**  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. ~~25~~ P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **CAPITAL CITY WELL DRILLING**  
 (CONTRACTOR)

Date started 2/13, 20 03  
 Date completed 2/15, 20 03

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
<u>25+</u>			
Draw Down (Feet Below Static)			
<u>25</u>			
Time (Hours)			
<u>3 HRS</u>			

Address **20 KIT KAT DRIVE**  
 (CONTRACTOR)  
**CARSON CITY, NV 89706**

Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed Rick Crane  
 By driller performing actual drilling on site or contractor  
 Date 2/16/03

RECEIVED  
 13 FEB 27 AM 11:19  
 STATE ENGINEERS OFFICE