

4 wells

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89580
Permit No. 212
Basin

NOTICE OF INTENT NO. 24475

1. OWNER TRC/Allen Geo Science
MAILING ADDRESS 9700 Reseda Blvd.
Suite 103 Northridge, CA
2. LOCATION NE 1/4 SE 1/4 Sec 36 T. 20 N/S R. 60 E Clark County
PERMIT NO. 138-36-201-0031 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. Domestic Municipal/Industrial Irrigation Test Stock
 Monitor Air Rotary RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0"	4"	4"
Type II		4"	12"	8"
Shads w/ gravel		1	6	5
Silly Sabon		6	12	6
Caliche		12	14	2
Silly clay		14	18	4
Caliche		18	19	1
Silly sand		19	26	7

8. WELL CONSTRUCTION
Depth Drilled 26 Feet Depth Cased 25 Feet
HOLE DIAMETER (BIT SIZE)
From 1 1/2 Inches To 0 Feet 26 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
4.50 56.40 0.250 0 25

Perforations:
Type perforation Machine Slotted
Size perforation .020 feet to 25 feet
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Coal of Quality Contaminated

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services
Address 7150 Placid Contractor
Las Vegas, NV

Gravel Packed: Yes No
From 25 feet to 8 feet
Surface Seal: Yes No Seal Type: Neat Cement Cement GROUT Concrete GROUT
Depth of Seal 8
Placement Method: Pumped Poured

7. WELL TEST DATA
TEST METHOD: Bailor Pump Air Lift
G.P.M. (Feet Below Static) Time (Hours)

Date started 12/17/2003
Date completed 12/18/2003