

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24489

1. OWNER Patty Matheny ADDRESS AT WELL LOCATION 401 S. 2<sup>nd</sup> St.  
 MAILING ADDRESS Beatty, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 7 T. 12 N/S R. 47 E. Beatty County  
 PERMIT NO. 18-266-05 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other USA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	4"	4"
Type II		4"	12"	8"
Sand w/gravel		1	6	5
Silty Sand		6	8	2
Sand w/gravel		8	13	5
Sand		13	16	3
Sand w/gravel	X	16	19	3
silty clay		19	22	3
Sand w/gravel		22	25	3

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
8 3/4 Inches \_\_\_\_\_ Feet 25 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.50</u>		<u>Sch. 40 PVC</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation Machine Sl-H-d  
 Size perforation .020  
 From 25 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 17  
 Placement Method:  Pumped  Poured  
 Concrete Grout

Gravel Packed:  Yes  No  
 From 25 feet to 17 feet

DCNR/DWR  
 RECEIVED  
 JUN 10 2003  
 LAS VEGAS OFFICE

Date started 3/11, 2003  
 Date completed 3/11, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Geal °F Quality Ca<sup>2+</sup> Magn<sup>2+</sup> Ca<sup>2+</sup>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eagle Drilling Service Contractor  
 Address 7150 Plover St. Contractor  
Las Vegas, NV

Nevada contractor's license number issued by the State Contractor's Board 51266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193

Signed Victor Lee  
 By driller performing actual drilling on site or contractor  
 Date 06/09/03