WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 69586
Permit No.
Basin 212

NOTICE OF INTENT NO. 24422

1. OWNER Secore
MAILING ADDRESS 1515 E. Tropicana Ave Suite 200 Las Vegas, Nv
ADDRESS AT WELL LOCATION 3330 W. Tropicana Ave Las Vegas, NV

2. LOCATION SW ¼ SW ¼ Sec. 20 T. 21 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources
162-20-402-003 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphalt | | 0 | 4" | 4" |
| Type II | | 4" | 12 | 8" |
| Sand w/gravel | | 1 | 7 | 6 |
| Silty Sand | | 6 | 13 | 7 |
| Caliche | | 13 | 15 | 2 |
| Silty Sand w/gravel | | 15 | 16 | 1 |
| Silty Sand | | 16 | 18 | 2 |
| Caliche | | 18 | 19 | 1 |
| Silty clay | | 19 | 21 | 2 |
| Clay | | 21 | 23 | 2 |
| Caliche | | 23 | 24 | 1 |
| Silty Sand | | 24 | 27 | 3 |
| Silty Sand w/gravel | | 27 | 28 | 1 |
| Silty Clay | | 28 | 34 | 6 |
| Clay | | 34 | 36 | 2 |
| Sand w/gravel | | 36 | 38 | 2 |
| Silty Sand | | 38 | 42 | 4 |
| Silty clay | | 42 | 46 | 4 |

DCNR/DWR
RECEIVED
JUN 10 2003
LAS VEGAS OFFICE

Date started 01/02, 2003
Date completed 01/02, 2003

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 46 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 11.50 | 0 | 46 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.50 | | Sch 40 PVC | 0 | 45 |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine Slotted
Size perforation .020
From 45 feet to 10 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 7
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 45 feet to 7 feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Contaminated

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services Contractor
Address 7150 Placid Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193
Signed Victor [illegible] By driller performing actual drilling on site or contractor
Date 01/29/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627