

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 895954
Permit No. 218
Basin

NOTICE OF INTENT NO. 24876

1. OWNER WAND-O-MATIC
MAILING ADDRESS 3910 E Arnold Ln #102
LAS VEGAS NV 89120
NORTH LAS VEGAS Clark County

2. LOCATION NE 1/4 S10 1/4 Sec 11 T 20 S 139-11-203-011
PERMIT NO. R-1180 Issued by Water Resources Parcel No. 139-11-203-011 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. Domestic Municipal/Industrial
 Irrigation Test Stock Air Other HSA

5. WELL TYPE
 Cable Rotary RVC
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>GRAVELLY SAND</u>		<u>00</u>	<u>20</u>	<u>20</u>
<u>GRAVELLY CORRUES</u>		<u>20</u>	<u>8.0</u>	<u>6.0</u>
<u>SANDY CLAY</u>		<u>8.0</u>	<u>15.0</u>	<u>7.0</u>
<u>CLAYEY SAND</u>		<u>15.0</u>	<u>30.0</u>	<u>15.0</u>
<u>SILTY SAND</u>		<u>30</u>	<u>50.0</u>	<u>20.0</u>

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 50 Feet
HOLE DIAMETER (BIT SIZE)
1 1/2 Inches From 0 Feet To 50 Feet
0 Inches Feet
0 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.50</u>		<u>5/16</u>	<u>40</u>	<u>30.0</u>
				<u>0.0</u>

Perforations: Type perforation MACHINE SLANTED
Size perforation 0.20 feet to 30.0 feet
From 50.0 feet to 30.0 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 1' Cement Grout
Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
From 50.0 feet to 27.0 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ERILE DELONG SERVICES
Address 7180 Pharo St Contractor
LAS VEGAS 89119 Contractor
Nevada contractor's license number 51266
Nevada driller's license number issued by the Nevada Contractor's Board 2202
Division of Water Resources, the on-site driller
Signed [Signature] by driller performing actual drilling on site or contractor
Date 5/16/03

7. WELL TEST DATA
TEST METHOD: Bailor Pump Air Lift
G.P.M. (Feet Below Static) Time (Hours)

Date started 3/24 2003
Date completed 3/26 2003