WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89597
Permit No.
Basin 212

NOTICE OF INTENT NO. 24486

1. OWNER Stewart Environmental
MAILING ADDRESS
ADDRESS AT WELL LOCATION 6076 Las Vegas Blvd. Las Vegas NV

2. LOCATION SE ¼ SW ¼ Sec. 32 T. 21 N/S R. 61 E. Clark County
PERMIT NO. R-1175 Issued by Water Resources
162-32-802-013 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Casing was perforated from				
70' B.G.L. to 140' B.G.L.				
Perforating operations were				
Halted due to apprehensions of				
tools being lodged in casing.				
A waiver of perforating was requested				
and granted. # R-1175				
perforations are 3" long by 3/8" wide				
perforated 4 times per foot.				
Well was abandoned from bottom to				
top using neat cement (24 sack)				
Cement was pumped				
Tremie hose consisted of 2" x 0.059				
wall thickness				
Manufacturer of hose = Sunflow Inc				
code SF-10				

Date started 2/10, 2003
Date completed 2/11, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump/DWA ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED 2003 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services (Contractor)
Address 7150 Placid St. (Contractor)
Las Vegas NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
Signed (By driller performing actual drilling on site or contractor)
Date 3/5/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627