WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89598
Permit No.
Basin 212

NOTICE OF INTENT NO. 24484

1. OWNER Stewart Environmental
MAILING ADDRESS
ADDRESS AT WELL LOCATION 6176 Las Vegas Blvd Las Vegas, NV

2. LOCATION SE ¼ SW ¼ Sec. 32 T. 21 N/S R 61 E. Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 162-32-802-013 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ PVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0.0	10.0	10.0
Gravely clay		10.0	14.0	4.0
Sandy clay		14.0	21.0	7.0
Cement Gravel		21.0	23.0	2.0
Gravely clay		23.0	42.0	19.0
Cement Gravel		42.0	45.0	3.0
Caliche		45.0	70.0	25.0
Gravely clay		70.0	80.0	10.0
Sandy clay		80.0	110.0	30.0
Gravely clay		110.0	140.0	30.0
Sandy clay.		140.0	145.0	5.0

BOND/OWT
RECEIVED
LAS VEGAS OFFICE

Date started 2/11, 2003
Date completed 2/13, 2003

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 145' Feet Depth Cased 145' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 1/2 Inches		0 Feet	145' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.250		Sch 40 PVC	105'	Surface

Perforations:
Type perforation Slotted (Machine)
Size perforation .020
From 145' 145.0 feet to 105.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 145.0 feet to 100.0 feet

9. WATER LEVEL
Static water level 80.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services (Contractor)
Address 7150 Placid St (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
Signed (By driller performing actual drilling on site or contractor)
Date 3/10/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627