

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24779

1. OWNER FREHNER CONSTRUCTION ADDRESS AT WELL LOCATION OWENS & 1ST.  
 MAILING ADDRESS 4040 FREHNER RD. (ROAD PARCEL) LAS VEGAS, NV  
 LAS VEGAS, NV 89000  
 2. LOCATION SW 1/4 SW 1/4 Sec. 22 T. 20 N/S R. 61 E. CLARK County  
 PERMIT NO. DW1159 139-22-499-010 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other Dewater  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>3-40' Dewater wells</u>				
<u>Type II road base</u>		<u>0'</u>	<u>1'</u>	<u>1'</u>
<u>Silt</u>		<u>1'</u>	<u>9'</u>	<u>8'</u>
<u>Clay</u>		<u>9'</u>	<u>14'</u>	<u>5'</u>
<u>White silty clay</u>	<u>x</u>	<u>14'</u>	<u>35'</u>	<u>21'</u>
<u>white clay</u>		<u>35'</u>	<u>40'</u>	<u>5'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 40' Feet Depth Cased 40' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
24" Inches 0' Feet 40' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>	<u>36.71</u>	<u>1.250</u>	<u>0'</u>	<u>40'</u>

Perforations: Machine  
 Type perforation \_\_\_\_\_  
 Size perforation 1/4" x 2 1/2" x 3 rows @ 13'  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No 40'  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 5/1/03, 20 \_\_\_\_\_  
 Date completed 5/1/03, 20 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC. Contractor  
 Address 4015 West Tompkins Ave. Contractor  
LAS VEGAS, NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board 18917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABD82161  
 Signed David  
 By driller performing actual drilling on site or contractor  
 Date 5/21/03