SEC 26 AABA 1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 69619
Permit No. 77453
Basin 162

NOTICE OF INTENT NO. 23803

1. OWNER Robert Rolling
MAILING ADDRESS PO Box 31 Pahrump NV 89041
ADDRESS AT WELL LOCATION 1811 E Simkins Pahrump NV

2. LOCATION NW/NE ¼ Sec. 26 T. 19 N/S R. 53 E. Nye County
PERMIT NO. ____ Issued by Water Resources
27-361-02 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soft Gravel		0	90	
Very Hard Gravel		91	170	
Semi Hard Gravel		171	220	
Very Hard Gravel		221	303	
Gravely - loose		304	310	
Hard		311	313	
Gravely - loose		314	360	
Very Hard		361	370	
Gravely - loose		371	390	
Soft		391	475	
Water At	304			
	355			
	385			
	430			

NR/DWR RECEIVED JUN 19 2003 LAS VEGAS OFFICE

Date started 3-10 19 2003
Date completed 3-21 19 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 475 Feet Depth Cased 475 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	475 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.188	0	475

Perforations:
Type perforation SLOT
Size perforation 1/8
From ____ feet to ____ feet
From 475 feet to 375 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 475 feet

9. WATER LEVEL
Static water level 203 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gatzke Drilling Contractor
Address PO Box 6678 Pahrump Contractor
NV 89041
Nevada contractor's license number issued by the State Contractor's Board 36415
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1650
Signed ____ by driller performing actual drilling on site or contractor
Date ____

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627