

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23806
1411 E. BLUE RIDGE AVE

1. OWNER STEVEN VERWER ADDRESS AT WELL LOCATION 1411 E. BLUE RIDGE AVE
PARLUMP
 MAILING ADDRESS 1411 E. BLUE RIDGE AVE PARLUMP
 2. LOCATION NE 1/4 NW 1/4 Sec. 22 T. 19 N/S R. 53 E. N4E County CLATSOP
 PERMIT NO. 29-304-10 COUNTY PLACER III
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT		0	15	
CLAY		16	30	
Caliche		31	37	
CLAY		38	46	
Caliche + clay		47	60	
Rocky		61	65	
CLAY + Caliche STREAKS		66	101	
GRAVELY		102	107	
CLAY + Caliche		108	137	
HARD		138	145	
CLAY + Caliche STREAKS		146	185	
GRAVELY		176	195	
WATER AT	102 146 176			

8. WELL CONSTRUCTION
 Depth Drilled 195 Feet Depth Cased 195 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 195 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>	<u>SC440</u>	<u>0</u>	<u>195</u>

Perforations:
 Type perforation 5/10T
 Size perforation 0.20
 From _____ feet to _____ feet
 From 195 feet to 165 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 50 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Garza Drilling Contractor
 Address PO BOX 6622 PARLUMP NV Contractor

Date started 3-7 RECEIVED 2003
 Date completed 3-8 19
2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Drawdown (Feet Below Static)	Time (Hours)
	<u>LAS VEGAS OFFICE</u>	

Nevada contractor's license number 36415 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1650
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-10-03