

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23907  
3921 S RAINBOW

1. OWNER Joe + Imelda Martin ADDRESS AT WELL LOCATION PAHRUMP NV  
 MAILING ADDRESS 3921 S RAINBOW  
 2. LOCATION SW 1/4 SE 1/4 Sec. 31 T 20S R 59 E Nye County CLAYTON VALLEY  
 PERMIT NO. 41-242-10 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DIRT		0	15	
CLAY		16	59	
CLAY + CALICHE STRAKS		60	95	
CLAY + CALICHE STRAKS		96	165	
WATER	96			

DCNR/DWR RECEIVED  
 JUN 09 2003  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 165 Feet Depth Cased 165 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 165 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC	SC40	0	165

Perforations:  
 Type perforation SLOT  
 Size perforation .020  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 165 feet to 135 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 165 feet

9. WATER LEVEL  
 Static water level 56 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GATZKE DRILLING Contractor  
 Address PO BOX 602 PAHRUMP NV Contractor  
 Nevada contractor's license number 36415 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1650  
 Signed [Signature]  
 Date 6-11-2003  
 By driller performing actual drilling on site or contractor

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift  

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

 Date started 3-16-2003  
 Date completed 3-17-2003