

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAG 534.340

NOTICE OF INTENT NO. 23742

1. OWNER John + Peggy ELLENBerg ADDRESS AT WELL LOCATION
 MAILING ADDRESS MOONSTONE AV. + PEORIA ST.
SANDY VALLEY NV
 2. LOCATION NW 1/4 SE 1/4 1/4 Sec. 26 T. 24 N. 56 E. CLARK County
 PERMIT NO. 200-26-801-009 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	6	6
CALICHE		6	9	3
CLAY		9	39	30
CALICHE		39	43	4
CLAY		43	54	11
CALICHE		54	57	3
CLAY		57	67	10
CALICHE	W.B	67	71	4
CLAY		71	91	20
CALICHE	W.B	91	99	8
CLAY		99	117	18
CALICHE	W.B	117	122	5
CLAY		122	133	11
CALICHE	W.B	133	140	7

DCNR/DWR
 RECEIVED
 JUN 16 2003
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>4.33</u>	<u>.316</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation SAW CUT
 Size perforation 1/2 INCH BY 6 INCH
 From 140 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 FT. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

Date started 5-24 2003
 Date completed 5-30 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO. Contractor
 Address P.O. BOX 3505 Contractor
RAHRUMP NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board 40020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1523
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-2-2003