



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50048

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER **BOB SECRIST**
 MAILING ADDRESS **390 JUNIPER**
ELKO, NV 89801

ADDRESS AT WELL LOCATION **SO SIDE OF MARSHALL AVE**
BETWEEN CHUCKAR & 2ND ST.

2. LOCATION **SW 1/4 SE 1/4 Sec. 23 T 32N**
 PERMIT NO. **027-050-003**
Issued by Water Resources Parcel No.

N/S R **55E E ELKO** County
LUCKY NUGGET #1
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL		0	1	1
GRAVEL & SAND		1	8	7
SILTSTONE		8	30	22
SILTSTONE & BOULDERS		30	60	30
SILTSTONE		60	200	140
SANDY SILTSTONE & GRAVEL	X	200	240	40

USED 23 BAGS OF 3/8 HOLE PLUG
 3 BAGS OF CEMENT

Surface Seal Method
 ok'd by Tom G.

RECEIVED
 03 MAY 14 AM 10:59
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Depth Drilled **240** Feet Depth Cased **240** Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
10 5/8 Inches	0	240	Feet
Inches			Feet
Inches			Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	240

Perforations:
 Type perforation **MILLSLOT**
 Size perforation **3/16 X 3**
 From **220** feet to **240** feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal **50**
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From **50** feet to **240** feet

9. WATER LEVEL

Static water level **135** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **C** °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **HACKWORTH DRILLING, INC** Contractor
 Address **P.O. BOX 850** Contractor

ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board **020582**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1689**

Signed *Dennis Deussen*
 By driller performing actual drilling on-site or contractor

Date **4/23/2003**

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.		
18		4