

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 89710
 Permit No. 15816
 Basin W62

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24734

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER BINION'S RANCH ADDRESS AT WELL LOCATION 751 E. BASIN
 MAILING ADDRESS 751 E. BASIN
PAHRUMP, NV 89048

2. LOCATION SE 1/4 NE 1/4 Sec. 15 T 20S N/S R 53E E NYE County
 PERMIT NO. 35-311-02 Issued by Water Resources Parcel No. 35-311-02 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	80	80
CALICHE	WB	80	100	20
CLAY		100	135	35
CALICHE	WB	135	160	25
CLAY		160	190	30
CALICHE	WB	190	250	60
GRAVEL	WB	250	265	15

PLUG OLD WELL
 PERFORATE WELL AND
 PUMP NEAT CEMENT
 THROUGH TRIMMIE PIPE
 TO BOTTOM

DCNR/DWR
 RECEIVED
 JUN 24 2003
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 265 Feet
10.25 Inches 0 Feet 265 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	265

Perforations:
 Type perforation SAW CUT
 Size perforation 1/8 X 3

From 95 feet to 265 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 265 feet

Date started 6/10/2003, 19
 Date completed 6/13/2003, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 130 feet below land surface
 Artesian flow _____ G.P.M.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063

Signed Ron Toney
 By driller performing actual drilling on-site or contractor
 Date 6/16/03