WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89725
Permit No.
Basin 212

NOTICE OF INTENT NO. 25294

1. OWNER SOUTHERN NEVADA WATER AUTHORITY
MAILING ADDRESS 1900 E. FLAMINGO RD.
LAS VEGAS NEVADA

ADDRESS AT WELL LOCATION ~~[illegible]~~

2. LOCATION NW ¼ SW ¼ Sec. 29 T. 21 N/S R. 63 E. CLARK County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ ~~Domestic~~ DEWATER ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other BUCKET

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 11 WELLS | | | | |
| SILT | | 0 | 8 | 8 |
| CLAY | | 8 | 14 | 6 |
| COARSE SAND W/GRAVEL | ✓ | 14 | 28 | 14 |
| CALICHE/REFUSAL | | 28 | ? | |

DCNR/DWR RECEIVED JUN 16 2003 LAS VEGAS OFFICE

Date started JUNE 11, 2003, 19
Date completed JUNE 11, 2003, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 28 Feet Depth Cased 28 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 36 Inches | 0 Feet | 28 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 12 | 15 | .250 | 0 | 8 |
| | | | | |

Perforations:
Type perforation LOUVERED
Size perforation .040
From 8 feet to 28 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10
Placement Method: ☐ Pumped ☒ Poured COLLAPSED
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 28 feet

9. WATER LEVEL
Static water level 1 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name KELLEY DEWATERING Contractor
Address 5175 CLAY AVE Contractor
WYOMING, MICHIGAN 49548
Nevada contractor's license number issued by the State Contractor's Board 50826
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS 2149
Signed [signature] By driller performing actual drilling on site or contractor
Date JUNE 17, 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627