

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO 22031

1. OWNER Catholic Charities of Southern Nevada ADDRESS AT WELL LOCATION 1501 N. Las Vegas Blvd.
 MAILING ADDRESS P.O. Box 1926 Las Vegas NV 89101
Las Vegas NV 89125

2. LOCATION NE 1/4 NE 1/4 Sec 27 T 20S N/S R 61 E County Clark

PERMIT NO _____ Issued by Water Resources 139-27-503-006 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface cover was damaged by construction equipment.				
Water level measured at 19.5' Depth sounded at 32 feet.				
Casing removed; borehole remained intact.				
Borehole plugged with sodium bentonite chips to the surface.				

8. WELL CONSTRUCTION

Depth Drilled 32 Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	To	Feet
<u>5 1/2</u>	<u>0</u>	<u>32</u>	<u>32</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>0.308</u>	<u>0</u>	<u>32</u>

Perforations:

Type perforation Factory slot PVC
 Size perforation 0.020 inch

From 10 feet to 32 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method Pumped Poured
 Gravel Packed: Yes No

From _____ feet to _____ feet

9. WATER LEVEL

Static water level 19.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.F.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATE

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Converse Consultants Contractor
 Address 731 Pilot Road, Suite H, Las Vegas NV 89119 Contractor

Nevada contractor's license number
 Issued by the State Contractor's Board 48947
 Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller M 1589

Signed Ronald T. Wilson
 By driller performing actual drilling on-site or contractor

Date 6-19-03

7. WELL TEST DATA

TEST METHOD	Bailer	Pumped	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	