

OFFICE USE ONLY  
 Log No. 89762  
 Permit No. 69446T  
 Basin 203

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24729

1. OWNER Laird and DecAnn Whipple ADDRESS AT WELL LOCATION Panaca Junction  
 MAILING ADDRESS and U.S. 93

2. LOCATION SW 1/4 SW 1/4 Sec. 5 T. 2 N. R. 68 E Lincoln County  
 PERMIT NO. 69446T | 12-110-19 | Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material         | Water Strata | From | To  | Thick-ness |
|------------------|--------------|------|-----|------------|
| Sandy loam       |              | 0    | 7   | 7          |
| Sand, clay       |              | 7    | 25  | 18         |
| clay             |              | 25   | 28  | 3          |
| sandy clay       |              | 28   | 55  | 27         |
| silt sand        | X            | 55   | 110 | 55         |
| silt sand gravel | X            | 110  | 158 | 48         |
| clay - red       |              | 158  | 170 | 12         |

8. WELL CONSTRUCTION  
 Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)  
 From 24 Inches 0 Feet 170 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>16</u>          | <u>52</u>           | <u>.312</u>             | <u>0</u>    | <u>170</u> |

Perforations:  
 Type perforation Factory milled  
 Size perforation 3/16 x 3"  
 From 50 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 170 feet

9. WATER LEVEL  
 Static water level 62 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 58 °F Quality Fair

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address P.O. Box 4220 Contractor  
Pahrump Nv. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 047333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238  
 Signed Bryan Anzalone  
 By driller performing actual drilling on site or contractor  
 Date June 10, 2003

Date started Apr. 20 2003  
 Date completed May 25 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

|                | G.P.M.      | Draw Down (Feet Below Static) | Time (Hours)   |
|----------------|-------------|-------------------------------|----------------|
| <u>Apr. 25</u> | <u>2500</u> | <u>16'</u>                    | <u>100 hrs</u> |