WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89783
Permit No.
Basin 2B

NOTICE OF INTENT NO. 24813

1. OWNER Kerr McGee Chemical
MAILING ADDRESS 8000 W Lake Mead Henderson, NV
ADDRESS AT WELL LOCATION 8000 W Lake Mead Henderson, NV

2. LOCATION NW ¼ SE ¼ Sec. 12 T. 22 N/S R 62 E Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 17812701001 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty gravelly Sand		0	20	
Silty Sandy gravel		20	33	
Sandy Clayey silt		33	35	
Calichified Sandy gravel		35	39	
Sand		39	44	
Clayey Silt		44	45	
Well #M17A				

DCNR/DWR
RECEIVED
JUL 01 2003
LAS VEGAS OFFICE

Date started June 18, 2003
Date complated July 1, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 Inches	0 Feet	45 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2				

Perforations:
Type perforation Screen
Size perforation
From 35 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 5 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 30 feet to 5 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Testing Engineers of Nev. (Contractor)
Address 6280 S. Valley View (Contractor)
Las Vegas, NV
Nevada contractor's license number issued by the State Contractor's Board 54243
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2229
Signed [signature] By driller performing actual drilling on site or contractor
Date July 1, 2003

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627