WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 59804
Permit No.
Basin 210

CSVM-6
NOTICE OF INTENT NO. 24755

1. OWNER Southern Nevada Water Authority
MAILING ADDRESS 1001 S. Valley View Blvd.
Las Vegas, Nevada 89153

ADDRESS AT WELL LOCATION 3 miles E. of us93 on st168 then 2.5 miles N.

2. LOCATION SW ¼ NW ¼ Sec. 11 T. 13 S N/S R. 63 E. Clark County
PERMIT NO. R-1169 (Issued by Water Resources) 009-00-001-004 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium (clay, silt, grav)		0	370	370
Carbonate (fine grain limestone)		370	710	340
Detrital (shale, trace dolomite)		710	730	20
Carbonate (fine grain limestone calcite, sandstone)		730	1200	470

Date started March 10 20 03
Date completed March 23 20 03

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M	Draw Down (Feet Below Static)	Time (Hours)
100		2 Hours

8. WELL CONSTRUCTION
Depth Drilled 1200 Feet Depth Cased 1160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
20 Inches	0 Feet	50 Feet
16 Inches	50 Feet	410 Feet
10 Inches	410 Feet	1200 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		Sched. 80	1160	+2

Perforations:
Type perforation Factory Slotted
Size perforation 0.10 x 2.5
From 1160 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 410
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 435 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 91.4 °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge

Name Eklund Drilling Company, Inc. (Contractor)
Address P.O. Box 2748, 606 Union Pacific Way, Elko, Nevada 89803 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0030823

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1819

Signed Greg Secrist (By driller performing actual drilling on site or contractor)

Date March 31, 2003

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12/01)