WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39805
Permit No.
Basin 210
CSVM-4
NOTICE OF INTENT NO. 24756

1. OWNER Southern Nevada Water Authority
MAILING ADDRESS 1001 S. Valley View Blvd
Las Vegas, Nevada 89153

ADDRESS AT WELL LOCATION Coyote Springs Valley, approximately 1.5 miles South Rainbow Road

2. LOCATION NW ¼ SW ¼ Sec. 13 T. 11 S N/S R. 63 E. Lincoln County
PERMIT NO. R-1094 Issued by Water Resources
008-201-04 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium. silt, sand, gravel		0	270	270
Carbonate. fine grain dolomite & calcite		270	1605	1335

Date started March 23, 2003
Date completed March 28, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
33		2 Hours

8. WELL CONSTRUCTION
Depth Drilled 1605 Feet Depth Cased 1600 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
20 Inches		0 Feet	20 Feet
16 Inches		20 Feet	310 Feet
10 Inches		310 Feet	1605 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		Sched. 80	1600	+2

Perforations:
Type perforation Factory Slotted
Size perforation 0.10 x 2.5
From 1580 feet to 800 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 310
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 966.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 98.6 °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co., Inc. Contractor
Address P.O. Box 2748, Contractor
605 Union Pacific Way, Elko, Nevada 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1819
Signed Greg Secrist By driller performing actual drilling on site or contractor
Date March 31, 2003

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01)