

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49634

1. OWNER Dr. Harry Fry ADDRESS AT WELL LOCATION undeveloped
MAILING ADDRESS 840 E street Sparks, NV 89431
2. LOCATION NE 1/4 NE 1/4 Sec 3 T 17 R 20 E Washoe County
PERMIT NO. M/O 1277A Parcel No. 017-410-40+41 Subdivision Name Majestic Ranch Estates II

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Boulders, gravel, sand and clay</u>		<u>0</u>	<u>22</u>	<u>22</u>
<u>Brown gravel and clay + silt</u>		<u>22</u>	<u>32</u>	<u>10</u>
<u>Dark brown sandy clay w/ gravel</u>	<u>X</u>	<u>32</u>	<u>45</u>	<u>13</u>

8. WELL CONSTRUCTION
Depth Drilled 45 Feet Depth Cased 43 Feet
HOLE DIAMETER (BIT SIZE)
From 6 Inches To 4.5 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>0.7</u>	<u>0.15</u>	<u>0</u>	<u>43</u>

Perforations:
Type perforation Factory slotted
Size perforation 0.62"
From 33 feet to 43 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 29 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 31 feet to 44 feet

9. WATER LEVEL
Static water level 20.0 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good-clear

Date started 3-17, 2003
Date completed 4-6, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>MW-6</u>	<u>73</u>	<u><1'</u>	<u>1.0</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Peter Herrera Contractor
Address 9424 Morehouse Pl. Las Vegas, NV 89123 Contractor
Nevada contractor's license number issued by the State Contractor's Board 14291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2241
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 4/24/03