

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49634

1. OWNER Dr. Harry Fry ADDRESS AT WELL LOCATION undeveloped
 MAILING ADDRESS 840 I Street Sparks, NV 89431
 2. LOCATION NW 1/4 NE 1/4 Sec. 3 T 17 S R 20 E Washoe County
 PERMIT NO. M/0.1277A Parcel No. 017-410-40+41 Subdivision Name Majestic Ranch Estates II

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Red-Orange silty sand w/ gravel</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>Red-brown clayey sand</u>		<u>8</u>	<u>20</u>	<u>12</u>
<u>Brown sandy clay slightly silty</u>		<u>20</u>	<u>35</u>	<u>15</u>
<u>Brown clay + sandy claystone</u>		<u>35</u>	<u>53</u>	<u>18</u>
<u>Brown clayey sand + claystone w/ sand stringers</u>	<u>X</u>	<u>53</u>	<u>60</u>	<u>7</u>

8. WELL CONSTRUCTION
 Depth Drilled 60 Feet Depth Cased 57 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 60 Feet
 From 0 Feet To 60 Feet
 From 0 Feet To 60 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>0.7</u>	<u>0.15</u>	<u>0</u>	<u>57</u>

Perforations:
 Type perforation Factory Slotted
 Size perforation 0.02"
 From 42 feet to 57 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 38' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No 38-40 bentonite chips
 From 40 feet to 59 feet

9. WATER LEVEL
 Static water level 41.3 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good-Murky

Date started 3-20, 2003
 Date completed 4-7, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>MW-4</u>	<u>2-3</u>	<u>8-10</u>	<u>1.0</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Peter Herrera
 Address 9424 Morehouse Pl. Las Vegas, NV 89123
 Nevada contractor's license number issued by the State Contractor's Board 14291
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2241
 Signed [Signature]
 Date 4/24/03