

OFFICE USE ONLY
Log No. 89869
Permit No. 038
Basin. 49634

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49634
ADDRESS AT WELL LOCATION undeveloped

1. OWNER Dr. Harry Fry ADDRESS AT WELL LOCATION undeveloped
MAILING ADDRESS 840 II Street Sparks, NV 89431
2. LOCATION NW 1/4 NE 1/4 Sec. 3 T. 17 S. R. 20 E. Washoe County
PERMIT NO. M/0 1277A Issued by Water Resources Parcel No. 017-410-4041 Subdivision Name Majestic Ranch Estates II

3. WORK PERFORMED
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Boulders, cobbles, silt, sand</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>Light brown sandy silt + gravel + clay</u>		<u>8</u>	<u>30</u>	<u>22</u>
<u>Red-brown sandy clay</u>		<u>30</u>	<u>40</u>	<u>10</u>
<u>Brown silty sand</u>	<u>X</u>	<u>40</u>	<u>48</u>	<u>8</u>
<u>Bm Claystone, sandy clay</u>		<u>48</u>	<u>56</u>	<u>8</u>

8. WELL CONSTRUCTION
Depth Drilled 56 Feet Depth Cased 54 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 56
Inches 0 Feet 56
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>0.7</u>	<u>0.15</u>	<u>0</u>	<u>54</u>

Perforations:
Type perforation Factory slotted
Size perforation 0.02"
From 44 feet to 54 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 39 Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No 39-41 Bentonite chips
From 41 feet to 56 feet

9. WATER LEVEL
Static water level 40.4 30.80 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality good-murky

Date started 3-21 2003
Date completed 4-8 5-3 PAH 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>MW-3</u>	<u>2-3</u>	<u>10-12</u>	<u>1.0</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge
Name Rter Herrera Contractor
Address 9424 Morehouse Pl. Las Vegas, NV 89123 Contractor
Nevada contractor's license number issued by the State Contractor's Board 14291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2241
Signed PLA H
By driller performing actual drilling on site or contractor
Date 4/24/03