

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49634  
ADDRESS AT WELL LOCATION undeveloped

1. OWNER Dr. Harry Fry ADDRESS AT WELL LOCATION undeveloped  
MAILING ADDRESS 840 E Street Sparks, NV 89431  
2. LOCATION NW 1/4 NE 1/4 Sec 3 T 17 S R 20 E Washoe County  
PERMIT NO. M/O 1277A Parcel No. 017-410-40411 Subdivision Name Majestic Ranch Estates II

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Reddish brown sand + silty gravel</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Light brown sandy silt + clay</u>		<u>5</u>	<u>30</u>	<u>25</u>
<u>Brown clay sandy claystone w/ minor gravel + silt</u>	<u>X</u>	<u>30</u>	<u>52</u>	<u>22</u>
<u>1st water 41-44'</u>				

8. WELL CONSTRUCTION  
Depth Drilled 52 Feet Depth Cased 50.5 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 52  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>0.7</u>	<u>0.15</u>	<u>0</u>	<u>52</u>

Perforations:  
Type perforation factory slotted  
Size perforation 0.02"  
From 35.5 feet to 50.5 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 31  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No 31-33 Bestonite chips  
From 33 feet to 51 feet

9. WATER LEVEL  
Static water level 40 42.0 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature cold °F Quality good - cloudy

Date started 4-10, 2003  
Date completed 4-11, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>MW-1</u>	<u>2-3</u>	<u>4-6</u>	<u>1.0</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Peter Herrera  
Address 9424 Morehouse Pl. Las Vegas, NV 89123  
Nevada contractor's license number issued by the State Contractor's Board 14291  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2241  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 4/24/03