2" NESTED 3 STRING COMPLETION PIEZOMETER

89400 ~~[illegible]~~

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. ~~[illegible]~~ 89400
Permit No.
Basin 212

NOTICE OF INTENT NO. 25257

1. OWNER LVVWD
MAILING ADDRESS 293 S. VALLEY VIEW LAS VEGAS, NV
ADDRESS AT WELL LOCATION 293 S. VALLEY VIEW LAS VEGAS, NV

2. LOCATION NE ¼ NW ¼ Sec. 32 T. 20 N/S R. 61 E. CLARK County
PERMIT NO. (Issued by Water Resources) 139-32-101-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0.0	4.0	4.0
SILTY SAND W GRAVEL		4.0	11.0	7.0
CALICHE		11.0	13.0	2.0
SANDY GRAVEL		13.0	17.0	4.0
CLAY W SAND		17.0	30.0	13.0
CLAY W COBBLES		30.0	42.0	12.0
SILTY SAND		42.0	45.0	3.0
SILTY SAND W CLAY		45.0	60.0	15.0

Date started 7/8, 2003
Date completed 7/9, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11½ Inches		0 Feet	60 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0		Sch 40 PVC	[redacted]	[redacted]
			40.0	0.0
			18.0	0.0
			5.0	0.0

Perforations:
Type perforation MACHINE SLOTTED
Size perforation .020
From 60.0 feet to 40.0 feet
From 28.0 feet to 18.0 feet
From 10.0 feet to 5.0 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60.0 feet to 4.0 feet

9. WATER LEVEL
Static water level 16.6, 25.52, DRY feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING (Contractor)
Address 7150 PLACID ST. (Contractor)
LAS VEGAS, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-15-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627