

OFFICE USE ONLY  
 Log No. 89904  
 Permit No. \_\_\_\_\_  
 Basin 2120

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24881

1. OWNER BOB DENINO ADDRESS AT WELL LOCATION 2910 S. MARYLAND PARKWAY LAS VEGAS, NV  
 MAILING ADDRESS P.O. Box 711 DALLAS TX 75221  
 2. LOCATION SW 1/4 NW 1/4 Sec. 11 T. 21 N/S R. 61 E CLARK County  
 PERMIT NO. 162-11-301-001 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TYPE II FILL		0.0	4.0	4.0
SANDY GRAVEL		4.0	7.0	3.0
SILTY SAND		7.0	11.0	4.0
COBBLES		11.0	12.0	1.0
SILTY SAND w/GRAVEL		12.0	18.0	6.0
GRAVELLY SAND		18.0	25.0	7.0

DCND/DWR RECEIVED  
 JUL 17 2003  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 25.0 Feet Depth Cased 25.0 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/2 Inches To 0.0 Feet 25.0 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.250</u>		<u>Sch 40 PVC</u>	<u>5.0</u>	<u>0.0</u>

 Perforations:  
 Type perforation MACHINE SLOTTED  
 Size perforation .020  
 From 25.0 feet to 5.0 feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 2'  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 25.0 feet to 3.0 feet

Date started 6/8, 2003  
 Date completed 6/9, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 19.0 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EAGLE DRILLING Contractor  
 Address 7150 PLACID ST. LAS VEGAS, NV 89119 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 51266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-15-03