3 WELLS

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 899 V
Permit No.
Basin 212

NOTICE OF INTENT NO. 24495

1. OWNER BOB DENINO
MAILING ADDRESS P.O. BOX 711
DALLAS TX 75221

ADDRESS AT WELL LOCATION
5099 E. BONANZA RD.
LAS VEGAS, NV

2. LOCATION SE ¼ SE ¼ Sec. 29 T. 20 N/S R. 62 E CLARK County

PERMIT NO. Issued by Water Resources | Parcel No. 140-29-802-011 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TYPE II FILL		0.0	4.0	4.0
SANDY CLAY		4.0	7.0	3.0
CLAY W/ SAND		7.0	11.0	4.0
SANDY CLAY		11.0	17.0	6.0
SILTY SAND W CLAY		17.0	20.0	3.0
SANDY CLAY W GRAVEL		20.0	30.0	10.0

CONTROL RECEIVED JUL 2003 LAS VEGAS OFFICE

Date started 6/12, 2003
Date completed 6/13, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30.0 Feet Depth Cased 30.0 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 1/2 Inches		0.0 Feet	30.0 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.250		SCH 40 PVC	15.0	0.0

Perforations:
Type perforation MACHINE SLOTTED
Size perforation .020
From 30.0 feet to 15.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 2'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 30.0 feet to 12.0 feet

9. WATER LEVEL
Static water level 22.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING Contractor
Address 7150 PLACID ST Contractor
LAS VEGAS, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 512266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2202
Signed By driller performing actual drilling on site or contractor
Date 7-15-03

USE ADDITIONAL SHEETS IF NECESSARY

(Rev 12-01) (O)-627