

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46062

1. OWNER Washoe County Dept of Water Resources ADDRESS AT WELL LOCATION 55 South 15th Ave
 MAILING ADDRESS 4930 Energy Way Reno, NV 89502 Sparks, NV

2. LOCATION SF 1/4 NW 1/4 Sec B T 19 N R 20 E Washoe County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Proto-Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Gravel Silt	Dry	0	19	19
Gravel Sand Clay	moist	19	80	61
Sand Gravel Silt Brown	wet	80	115	35
Sand Silt Clay Dark Gray	wet	115	151	36
Sand Silt Brown	wet	151	177	26

8. WELL CONSTRUCTION
 Depth Drilled 177 Feet Depth Cased 177 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 0 Feet 177 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>Sch 40</u>		<u>0</u>	<u>152</u>

Perforations:
 Type perforation Factory Cut
 Size perforation 020
 From 152 feet to 177 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 147 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 150 feet to 177 feet

Date started 7-28 2003
 Date completed 7-30 2003

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ROBERT LONGYEAR Contractor
 Address 32 Stokes Dr. Po Box 1000 Dayton, NV 89403 Contractor
 Nevada contractor's license number issued by the State Contractor's Board DD10157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148T2
 Signed Bob Bay
 Date 8-16-03
 By driller performing actual drilling on site or contractor

RECEIVED
 08 AUG 20 11:10:57
 STATE ENGINEERS OFFICE