WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK
WPR-3

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90372
Permit No.
Basin 087

NOTICE OF INTENT NO. 46062

1. OWNER Washoe County Dept of Water Resources
MAILING ADDRESS 4930 Energy Way Reno, NV 89502
ADDRESS AT WELL LOCATION 55 South 15th Ave Sparks, NV

2. LOCATION SE ¼ NW ¼ Sec. 8 T. 19 N S R. 20 E. Washoe County

PERMIT NO. ..... Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Roto-Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel, Silt, Brown		0	11	11
Gravel, Sand		11	21	10
Gravel, Silt, Sand, Clay		21	86	65
Sand, Silt, yellow Brown		86	106	20

RECEIVED
03 AUG 20 AM 10:57
STATE ENGINEERS OFFICE

Date started 7·30· , 2003
Date completed 7·31· , 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 106 Feet Depth Cased 106 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	106 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch 40		0	83

Perforations:
Type perforation Factory Cut
Size perforation .020
From 83 feet to 103 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 78
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 81 feet to 106 feet

9. WATER LEVEL
Static water level ..... feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BOARY Longyear
Contractor
Address 32 Stokes Dr. PO. Box 1000
Contractor
Dayton, NV 89403

Nevada contractor's license number issued by the State Contractor's Board 0010157

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148T2

Signed [signature]
By driller performing actual drilling on site or contractor

Date 8·16·03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627